

SSO Bypass Event Tracker

Event Codes
1= SSO
2= Bypass
3= Basement

Date		Time		Location		Event	Rainfall Amount in Inches	Approx. Discharge	Reporting Party	Sample Taken Y/N
Begin	End	Begin	End	Manhole ID	Segment ID					
03/03/15	03/03/15	8:00 PM	8:30 PM	E6-MH-300		1	6.00	7,500 Gal	James Bradshaw	N
03/13/15	03/16/15	9:20 PM	7:00 AM	1801 E. Broadway		2	0.95	4.8 Mil Gal	Eli Robertson	Y
03/20/15	03/20/15	3:55 PM	3:55 PM	F6-MH-220		1	0.00	300 Gal	Bob Allard	N
03/26/15	03/28/15	8:30 AM	2:45 PM	1801 E. Broadway		2	1.52	5.2 Mil Gal	Joe Cornell	Y
04/01/15	04/02/15	5:00 PM	5:30 AM	1801 E. Broadway		2	0.76	1.4 Mil Gal	Joe Cornell	Y
04/02/15	04/04/15	5:00 PM	9:00 PM	1801 E. Broadway		2	1.16	7.6 Mil Gal	Joe Cornell	Y
04/03/15	04/03/15	8:30 AM	1:00 PM	J4-MH-120		1	1.16	4,600 Gal	Joe Cornell	N
04/18/15	04/18/15	1:26 PM	3:14 PM	J4-MH-120		1	1.03	24,000 Gal	Joe Cornell	N
04/18/15	04/19/15	12:05 PM	5:22 PM	1801 E. Broadway		2	1.03	3.76 Mil Gal	Joe Cornell	Y
05/15/15	05/16/15	11:05 AM	3:15 AM	J4-MH-120		1	1.21	30,000 Gal	Eli Robertson	N
05/15/15	05/18/15	11:05 AM	4:20 PM	1801 E. Broadway		2	1.91	8.81 Mil Gal	Eli Robertson	Y
05/24/15	05/28/15	7:26 AM	7:10 AM	1801 E. Broadway		2	1.92	13.54	Joe Cornell	Y
05/29/15	05/30/15	8:45 AM	18:25 PM	J4-MH-120		1	3.17	0.52	Joe Cornell	N
05/29/15	06/02/15	6:00 AM	6:00 AM	1801 E. Broadway		2	3.18	21.4	Joe Cornell	Y
06/16/15	06/17/15	6:45 PM	4:00 PM	F5-MH-095		1	6.48	63,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	3:00 PM	F5-MH-035		1	6.48	36,000	Spencer Welch	N

06/16/15	06/17/15	6:45 PM	4:00 PM	F5-MH-040	1	6.48	193,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	3:00 PM	F5-MH-005	1	6.48	36,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	5:00 PM	F5-MH-175	1	6.48	50,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	5:00 PM	G4-MH-005	1	6.48	50,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	10:00 PM	F5-MH-030	1	6.48	71,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	10:00 PM	F5-MH-010	1	6.48	136,500	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	10:30 AM	G5-MH-175	1	6.48	29,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	4:00 PM	FR5-MH-100	1	6.48	38,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	3:30 PM	E6-MH-340	1	6.48	172,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	10:30 AM	G7-MH-020	1	6.48	29,000	Spencer Welch	N
06/16/15	06/17/15	6:45 PM	1:00 PM	E6-MH-030	1	6.48	27,000	Spencer Welch	N
06/16/15	06/16/15	6:35 PM	10:30 PM	J4-MH-090	1	0.47	1,500	Eli Robertson	N
06/16/15	06/20/15	6:35 PM	8:00 AM	J4-MH-120	1	7.75	1.8	Eli Robertson	N
06/16/15	06/24/15	6:35 PM	11:00 AM	1801 E. Broadway	2	8.97	30.8	Eli Robertson	Y
06/26/15	06/28/15	8:00 AM	6:00 AM	1801 E. Broadway	2	1.05	4.16	Joe Cornell	Y
07/01/15	07/01/15	5:25 AM	4:00 PM	J4-MH-120	1	1.90	17,000	Joe Cornell	N
07/08/15	07/09/15	7:45 AM	4:00 AM	J4-MH-120	1	1.65	0	Joe Cornell	N
07/09/15	07/10/15	11:00 PM	5:00 AM	F5-MH-105	1	2.50	2,000	James Bradshaw	N
07/09/15	07/10/15	11:00 PM	5:00 AM	F5-MH-010	1	2.50	1,800	James Bradshaw	N
07/09/15	07/10/15	11:00 PM	5:00 AM	F5-MH-040	1	2.50	1,400	James Bradshaw	N
07/10/15	07/10/15	8:00 AM	9:30 PM	J4-MH-120	1	1.75	0.23	Stephen Myrick	N
07/01/15	07/18/15	5:25 AM	7:49 PM	1801 E. Broadway	2	8.29	64.87	Joe Cornell	Y
09/08/15	09/08/15	12:05 PM	3:00 PM	J4-MH-120	1	2.09	9,000	Eli Robertson	N
09/08/15	09/09/15	11:10 AM	7:09 AM	1801 E. Broadway	2	2.15	2.29	Eli Robertson	Y

11/17/15	11/18/15	12:00 PM	6:00 AM	J4-MH-090		1	5.21	270,000	Stephen Myrick	N
11/17/15	11/18/15	6:00 AM	6:00 AM	J4-MH-120		1	5.21	360,000	Stephen Myrick	N
11/16/15	11/19/15	8:16 AM	10:30 AM	1801 E. Broadway		2	5.21	12.23	Stephen Myrick	Y
11/17/15	11/17/15	10:30 AM	2:30 PM	West Broadway		1	5.21	12,000	Adam Applegate	N
11/17/15	11/17/15	10:30 AM	5:00 PM			1	5.21	39,000	Adam Applegate	N
11/17/15	11/17/15	10:30 AM	7:00 PM	West Broadway		1	5.21	102,000	Adam Applegate	N
11/27/2015	11/28/2015	7:00	7:00	J4-MH-120		1	2.34	144,100	Stephen Myrick	N
11/27/2015	12/3/2015	3:30 AM	6:30 AM	1801 E. Broadway		2	2.57	20.48 Mil	Stephen Myrick	Y
12/13/2015	12/14/2015	18:00	5:42	J4-MH-120		1	1.61	3,100	Joe Cornell	N
12/13/2015	12/16/2015	14:30	5:50	1801 E. Broadway		2	1.61	12	Joe Cornell	Y
12/26/2015	12/29/2015	4:05 AM	8:00 AM	J4-MH-120		1	8.13	270,000	Eli Robertson	N
12/27/2015	12/28/2015	9:00 AM	6:30 AM	J4-MH-090		1	7.78	216,000	Stephen Myrick	N
12/26/2015	1/5/2016	4:05	14:00	1801 E. Broadway		2	8.13	68 Mil	Eli Robertson	Y
Total Events						53				
SSOs						37				
Bypasses						16				
Backups						0				

Personnel, arrival time, & Remedy
Service tap was full of roots, Jet that night, return in the morning to jet again followed by the camera.
Plant Hydraulically Overloaded
Main was full of roots. Jetted to unpug and followed by the camera.
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded

Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Hydraulically Overloaded
Plant Flow Decreased
Plant Hydraulically Overloaded, Plant flow decreased.
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Plant Hydraulically Overloaded, Plant flow decreased.
Plant Hydraulically Overloaded
Heavy Rain, Plant Flow Decreased.
Plant Hydraulically Overloaded.

Plant Flow Decreased
Plant Flow Decreased
Plant Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Collection System Hydraulically Overloaded
Plant Flow Decreased
Plant Hydraulically Overloaded
Plant Flow Decreased
Plant Hydraulically Overloaded
Flow Decreased
Flow Decreased
Plant Hydraulically Overloaded
51 wet weather related
35 wet weather related, one service blockage, one main blockage
All wet weather related
None reported

